

No: 97/CC/DFO/HDH/2025-26

Office of the District Fire Officer
Karnataka Fire & Emergency Services
Hassan District Hassan-573201
Date: 31-03-2026.

To,
The Secretary
Sridevi Education Society®
Kuvempunagara, Channarayapattana
Hassan District-573116.

Sir,

Sub: Issue "Fire Safety Compliance Certificate" with respect to fire prevention,
Fighting and evacuation measures maintained at "Poornachandra Public School
(Dise No-29230515427)" building at Kuvempunagara, Channarayapattana, Hassan
District-573116.

Ref:- 01. Advice No: 37/FSR/DFO/HDH/2025-26. Dated: 09-01-2026.

02. Your request letter dated: 23-03-2026.

With reference to the above cited subject, as per reference (1) Fire safety recommendation certificate was issued to the premises "Poornachandra Public School (Dise No-29230515427)" building at Kuvempunagara, Channarayapattana, Hassan District-573116.

Now as per reference (2) the School management "Poornachandra Public School" submitted letter and requested for issue Fire Safety Compliance Certificate.

In this regard as per reference (3) above premises was re-inspected by me on 23-03-2026 & fulfilled the fire fighting systems and found the fire fighting systems are in good working condition during inspecting.


Under the above circumstances the Karnataka Fire & Emergency Services Department is issuing the 'Fire Safety Compliance Certificate' to "Poornachandra Public School (Dise No-29230515427)" building at Kuvempunagara, Channarayapattana, Hassan District-573116. subject to proper maintenance of fire fighting installations in good working conditions. This Fire Safety Compliance Certificate Valid up to 08-01-2027 and is renewable.

Copy with respects

DGP & DG

Karnataka Fire & Emergency Services, Bangalore-42

Yours faithfully



District Fire Officer 31/3/2026
Karnataka Fire & Emergency Service
Hassan District, Hassan Fire Station
HASSAN-573201

Office of the
District Fire Officer
Karnataka Fire and Emergency Services
Hassan District Hassan-573201
Date: 09-01-2026

To,
The Secretary
Sridevi Education Society®
Kuvempunagara, Channarayapattana
Hassan District-573116.

Sub : Issue of 'Fire safety recommendation' to existing "Poornachandra Public School(Dise No-29230515427)" building at Kuvempunagara, Channarayapattana, Hassan District-573116.

Ref : 01. Your request dated: 21-10-2025.

><><>*@*<><><

With reference to the subject above cited, the premises of existing "Poornachandra Public School(Dise No-29230515427)" building at Kuvempunagara, Channarayapattana, Hassan District-573116 was inspected by me on 01-11-2025 with respect to Fire evention, Fire fighting and Evacuation measures to be complied in the above premises and has submitted the details as under.

ANNEXURE-1

Group B Educational Buildings

***NBC-2016, Part-4, Table 7 (11) 3.1.3 Group B Educational Buildings
Sub Division B1 & B2***

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC 2016 are mandatory.)

Part-A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Secretary Sridevi Education Society® Kuvempunagara, Channarayapattana Hassan District-573116.
02	Name and Address of the premises.	:	Kuvempunagara, Channarayapattana Hassan District-573116.
03	Name and address of the Building owner	:	The Secretary Sridevi Education Society® Kuvempunagara, Channarayapattana Hassan District-573116.
04	Number of buildings	:	01 Building.
05	Number of floors	:	Ground + 02 Upper floors.
06	<u>Floor-wise details of occupancy:-</u>		



		:	Ground floor:- 09 Class rooms, Administration room & Wash rooms. First floor:- 09 Class rooms, Admin/Staff room & Wash rooms. Second floor:- 09 Class rooms, Admin/Staff room & Wash rooms.
07.	Height of the building	:	11.15 mtrs.
08.	Site area	:	2231.60 Sq. mtrs.
09.	Built-up area of each floor:-		
		:	Ground floor:- 463.60 Sq. Mtrs. First floor:- 463.60 Sq. Mtrs. Second floor:- 463.60 Sq. Mtrs.
10.	Total built-up area	:	1390.80 Sq. Mtrs.
11.	Surrounding properties:-		
	East (Front)	:	07.00 mtrs wide Tejaswi road.
	West (Rear)	:	Residential House.
	North (Side)	:	Vacant land.
	South (Side)	:	Residential House.
12.	Set-back area available around the building :-		
	East (Front)	:	Nil.
	West (Rear)	:	Nil.
	North (Side)	:	Nil.
	South (Side)	:	Nil.

Part-B. On inspection of this School premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
1.	Accessibility	The Premises is accessible from 07.00 Mtrs, wide Tejaswi road, Located on the Eastern side of the premises. This road hardened to carry weight of 45,000kgs.	Adequate.
2.	Number of entrances	01 entrance gate width of 06.00 mtrs has been provided.	Adequate.
3.	Number of	Number of the 02 no's.	Complied.



	staircases available	staircases		
		Width of staircases	1.30 mtrs.	
		Width of treads	30 Cms	
		Height of risers	15 Cms	
		No. of risers per flight	13 nos.	
		Height of handrails	0.60 mtrs.	
		Head room clearance	3.10 mtrs.	
4.	Diesel generator	Not provided.		Diesel generator of 15 KVA capacity should be provided to supply alternative power supply.
5.	Portable Fire extinguishers	Not provided		A. One Water mist extinguisher of 9 liters capacity should be kept near each staircase landing. B. One Mechanical foam extinguisher of 9 liters capacity & One ABC type extinguisher of 6Kgs capacity should be provided near Diesel Generator. C. One Co2 Type fire extinguisher of 4.5Kgs capacity should be provided near each electrical board & electrical room. D. One ABC type extinguisher of 6kgs capacity should be located as to be available within 15.00mtrs radius.
6.	First aid hose reel hose	Not provided.		Hose reel hose near the staircase (One hose reel hose system for every 1000 sq.mtrs) shall be provided. The hose reel hose min 19 mm size and 100 mm internal diameter made up of G.I 'C' class pipe and of adequate length to reach the farthest point of each floor



			should be provided with shut off branch having a nozzle of 5mm size. The hose reel hose should be connected at each landing of each building/ block/ wing/ tower.
7.	Terrace tank over respective tower terrace	Not provided.	Hose reel hose system should be connected to an over head tank of 5,000 ltrs capacity and further if basement is provided the tank capacity shall be increased to 10,000 ltrs capacity. (The water tank should be kept exclusively for firefighting purpose) Note: If the existing building is not capable of sustaining the weight of 5,000/10,000 ltrs. tank capacity provision shall be made to provide water tank on the side of the building with support from ground level by providing RCC column structure or MS column structure. If there is no option to provide even the above mentioned overhead tank provision shall be made to provide underground water tank of capacity with submersible pump of 5-7 HP capacity.
8.	At the terrace tank level with minimum pressure of 3.5 kg/cm ²	Not provided.	Hose reel hose system should be connected to an booster pump of 450 LPM or of 5 HP capacity. (Further the system should be connected to an alternative source of power supply)
9.	Escape routes	Not provided.	Directions in which the students have to move in the event of any emergency should be displayed in the corridor on each floor of thre



			buildings during evacuation.
10.	Fire order (Fire Safety plans)	Not provided.	A notice board have been indicated the action should be taken by the employees in case of any emergency should be displayed with the telephone number of Channarayapattana Fire Station i.e. 08176-200044 & 101 and the nearest Ambulance service and Police Station.
11.	No smoking board.	Not provided.	COTPA Sec-4, direction NO Smoking area smoking here is an offence board should be written in English & Kannada both language shall be prominently displayed at inside the entry / exit of the each floor of each buildings.
12.	Fire Siren	Not displayed.	A Fire Siren shall be installed in the premises to inform the inmates in case of fire emergency and evacuate the area.
13.	Nominate one Fire Nodal Officer	Not installed	A Fire Nodal Officer shall be nominate either from teaching or non teaching staff.
14.	Fire Fighting training	03 no's of Staff has been trained at District Fire Officer, Hassan District, Hassan Fire Station Premises, Hassan from 19-11-2025 to 20-11-2025.	Complied.
15.	<u>Fire precautionary measures :-</u> A) Explosive and flammable materials should not be stores in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B) Accumulation of combustile waste in and the premises should be avoided. C) The exit ways shall be always kept clear without any obstruction. D) Liquefied petroleum gas should not be stores in.the building. E) The doors shall not be kept locked / latched during working hours and shall		



be free from obstruction.

F) During the class hours the class room doors shall not be locked from inside to outside.

G) As per Honorable Supreme Court order all teachers and staffs shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety Day on April 14th of every year be conducting Fire Safety drills with co-ordinate Fire Service department.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing Fire Safety Recommendation of "Poornachandra Public School(Dis No-29230515427)" building at Kuvempunagara, Channarayapattana, Hassan District-573116 subject to condition and compliance of the above recommendations in Column-4 of serial-B within 3 months and compliance to the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issued."

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully



District Fire Officer
Karnataka Fire & Emergency Service
Hassan District, Hassan Fire Station
HASSAN-573201

Copy with respects

DGP & DG

Karnataka Fire & Emergency Services, Bangalore-42